

EU Declaration of Conformity
(No. FSTEC18005-03)

In accordance with of European Parliament and Council Decision No 768/2008/EC Annex III

Product model / product:

Product Battery Powered Carbon Monoxide Alarm
Model/type FireAngel CO-9B-XX, Angeleye CO-AE-9B-XX, FireAngel CO-9X-XX, AngelEye CO-AE-9X-XX
FireAngel CO-9X-10-XX, Angeleye CO- AE-9X-10-XX, FireAngel CO-9D-XX,
Angeleye CO-AE-9D-XX, FireAngel CO-FA-9B, FireAngel NM-CO-10X-XX
Siemens Delta Reflex 5TC1260 and 5TC1260-1, Pace Sensors CO-BG-01

XX- denotes country code;: AUS-Australia, BNL-Belgium & Netherlands
CEU-Central Europe, DE-Germany, EEU-Eastern Europe, EU-Generic European Variant
FR-France, INT-International, NEU-Northern Europe, PL-Poland, SEU-Southern Europe

Manufacturer:

Name FireAngel Safety Technology Limited
Address Vanguard Centre, Sir William Lyons Road, Coventry, CV4 7EZ, UK

This declaration is issued under the sole responsibility of the manufacturer.

Object of the declaration:

Product Battery Powered Carbon Monoxide Alarm
Specification 3 V DC supply, 85dB(A) alarm, Electrochemical sensor

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

2014/30/EU The Electromagnetic Compatibility Directive
2011/65/EU The Restriction of Hazardous Substances Directive (RoHS)

References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:

Reference & Date	Title
EN 50291-1:2010+A1:2012	Electrical apparatus for the detection of carbon monoxide in domestic premises Part 1: Test methods and performance requirements
EN50291-2:2010	Electrical apparatus for the detection of carbon monoxide in domestic premises Part 2: Electrical apparatus for continuous operation in a fixed installations in recreational vehicles and similar premises including recreational craft — Additional test methods and performance requirements.
EN 50270:2015	Electromagnetic compatibility. Electrical apparatus for the detection and measurement of combustible gases, toxic gases or oxygen



I.M Ballinger
Certification Manager
Signed for and on behalf of:
FireAngel Safety Technology Limited
12th Feb 2019, Coventry, UK