

Attestation

On 12 January 2012 Eurofins Product Testing A/S received a sample with the name

Protecta FR Brannplate 2-S 60x600x1200mm Protecta A/S

The floor covering sample has been selected by Protecta A/S as being representative for samples of this type.

The emissions were tested according to AgBB and the guidelines of the DIBt (AgBB - Committee for Health-related Evaluation of Building Products, DIBt – German Institute for Building Technology). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 in the latest versions, see the test report no. G12873.

Evaluation of the test result according to AgBB:

- Carcinogenic substances were not detectable after 3 and after 28 days.
- The sum of VOC ("TVOC") after 3 days was below the limit of 10 mg/m³.
- The sum of VOC ("TVOC") after 28 days was below the limit of 1 mg/m³.
- The sum of SVOC after 28 day was below the limit of 0.1 mg/m³.
- After 28 days the value R was calculated from the detected VOC with single concentrations above 5 μg/m³. This value R was below the limit of 1.
- The sum of VOC without LCI-value after 28 days was below the limit of 0.1 mg/m³.
- Formaldehyde after 28 days was below the limit of 120 μg/m³.

The tested product complies with the requirements of DIBt (October 2010) in combination with the NIK values from AgBB (May 2010) for use in the indoor environment.

19 March 2012

Thomas Neuhaus
Head of product emission test centre

Søren Ryom Villadsen

Analytical Service Manager

Eurofins Product Testing A/S Smedeskovvej 38 DK-8464 Galten / Denmark

Tel +45 70 22 42 76 Fax +45 70 22 42 75